

Branch Connections

CKT/Branch		Connected Bus ID		% Impedance, Pos. Seq., 100 MVA Base			
ID	Type	From Bus	To Bus	R	X	Z	Y
TRAFO PABRIK	2W XFMR	CUBICLE OUTGOING	LVMDP PELANGGAN	2.97	59.48	59.56	
TRAFO UTAMA	2W XFMR	Bus GI 150kV	Bus GI-20kV	0.46	20.83	20.83	
Cable XLPE-1	Cable	Bus GI-20kV	TM-11	1.58	1.49	2.17	0.0103915
Cable XLPE-2	Cable	TM-11'	CUBICLE INCOMING	1.13	1.06	1.55	0.0074225
SUTM AAAC 150mm	Line	TM-11	TM-11'	12.58	11.28	16.89	0.0121427
CB3	Tie Breakr	CUBICLE INCOMING	CUBICLE OUTGOING				